

DIN EN 3 APPROVAL CERTIFICATE

Approval number: **SP 46/97**

This is to certify that the "BAVARIA" DIN EN 3 fire extinguisher with 12 kg ABC fire extinguishing powder has been type approved with the above mentioned approval number.

Approval specifications: PZP 001 AZG dated 06.06.2018, DIN EN 3-7:2007 and DIN EN 3-10:2009

Test report no.: 20190492/B 350*) in conjunction with the approval certificate no. SP 46/97 dated 1997-12-23 and the supplements no. 1 until 4

Holder of the certificate: BAVARIA Brandschutz Industrie GmbH & Co. KG
Regensburger Straße 16, 93449 Waldmünchen, Germany

Production facility: BAVARIA Brandschutz Industrie GmbH & Co. KG
Regensburger Straße 16, 93449 Waldmünchen, Germany

Model name: Brandstop 12G-1 / Vole X-P 12 **Trade mark:** BAVARIA®

Assembly drawing no.: 12106-00.00 **List of parts no.** 12106-00.00

Fire extinguishing medium: ABC fire extinguishing powder
ABC BAVEX
Reference no. PL-8/94 **Operation device:** grip lever

Propellant: nitrogen **Special detail:** Nozzle according to drawing 1201-03.03

Test fire rating: 55 A and 233 B
according to DIN EN 3-7 **Range of operating temperature:** -30 °C to 60 °C

Notes: *) Modification / Supplementation: - ABC fire extinguishing powder Furex ABC Genius (reference no. SP 05/12) with the test fire rating 55 A and 233 B
- The fire extinguisher may be also distributed under the trademark „BAVARIA®“ by the company BAVARIA Egypt S.A.E., 17, Emad El Din St., Cairo-Egypt-P.O.Box: 2016/11111 Cairo


The fire extinguisher is tested in accordance with the Product certification schedule PZP 001 AZG and standard DIN EN 3-7. The fulfilment of the requirements is attested.

The production facility of the fire extinguisher is subject of the factory production control within the scope of a quality management system according to DIN EN 3-10 and is subject of surveillance by MPA Dresden GmbH.

The holder of the certificate is authorized to affix the above stated approval number on the marking label of the approved corresponding fire extinguisher as long as the results of our regular inspections, proceeded according to clause 10 of DIN EN 3-10, are satisfactory.

This approval certificate is valid solely for fire extinguishers which correspond with the submitted test samples and with the confirmed documents.

23 January 2020


Grad. Eng. (FH) Michael Habitzsch
Manager of the certification office
Vorlage 2.10 Rev.04

MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
www.mpa-dresden.de

Geschäftsführer: Thomas Hübler
Tel. +49(0)3731-20393-0
Fax +49(0)3731-20393110
E-Mail info@mpa-dresden.de

Amtsgericht Chemnitz HRB 28268
Steuernummer: 220/114/03364
USt-IdNr. DE291271296

Sparkasse Mittelsachsen
Poststraße 1a
09599 Freiberg
IBAN DE68 870520003115024672
BIC WELADED1FGX