

### EN 3 APPROVAL CERTIFICATE

**Approval number:** **SP 82/10**

This is to certify that the "BAVARIA<sup>®</sup>" EN 3 fire extinguisher with 2 kg ABC dry chemical powder has been type approved with the above mentioned approval number.

**Approval specifications:** EN 3-7 : 2004 + A1 : 2007 in conjunction with the requirements of EN 3-10 : 2009

**Test report no.:** 20160261/EG 125 <sup>\*)</sup> in conjunction with the approval certificate no. SP 82/10 dated 2010-05-31

**Holder of the certificate:** BAVARIA EGYPT S.A.E., 17, Emad El Din St., 11111 Cairo, Egypt

**Manufacturer:** BAVARIA EGYPT S.A.E., Gisir El Suez St. Block 109-Industrial Zone, Ismailia Desert Road, 11511 Cairo, Egypt

**Model name:** Champion 2 **Trade mark:** BAVARIA<sup>®</sup>

**Assembly drawing no.:** 2322-03 **List of parts no.** 2322-03

**Fire extinguishing medium:** ABC BAVARIA EXTRA POWDER **Operation device:** Key  
Reference no. SP 67/09

**Propellant:** Nitrogen, 15 bar at 20 °C **Special detail:** Nozzle diameter 4,5 mm

**Test fire rating:** 13 A and 89 B **Range of operating temperature:** - 30 °C to 60 °C  
according to EN 3-7

**Notes:** <sup>\*)</sup> Modification / Supplementation:  
- ABC BAVARIA SUPERLATIVE POWDER 45 / Reference no. SP 85/09  
- Distribution also under the trade mark „BAVARIA<sup>®</sup>“ by the company BAVARIA Brandschutz Industrie GmbH & Co. KG, 93449 Waldmünchen

The fire extinguisher is tested in accordance with the standard EN 3-7. Conformity to EN 3-7 is attested.

The manufacture of the fire extinguisher is subject of the factory production control within the scope of a quality management system according to EN 3-10 and is subject of surveillance by MPA Dresden GmbH.

The holder of the certificate is authorized to affix the above stated approval number on the marking label of the approved corresponding fire extinguisher as long as the results of our regular inspections, proceeded according to clause 10 of EN 3-10, are satisfactory.

This approval certificate is valid solely for fire extinguishers which correspond with the submitted test samples and with the confirmed documents.

17 March 2016



Grad. Eng. Bernd Ruhle  
Manager of the certification office



Vorlage 2.10 Rev.02

MPA Dresden GmbH  
Fuchsmühlenweg 6F  
09599 Freiberg  
www.mpa-dresden.de

Geschäftsführer: Thomas Hübler  
Tel. +49(0)3731-20393-0  
Fax +49(0)3731-20393110  
E-Mail info@mpa-dresden.de

Amtsgericht Chemnitz HRB 28268  
Steuernummer: 220/114/03364  
USt-IdNr. DE291271296

Sparkasse Mittelsachsen  
Poststraße 1a  
09599 Freiberg  
IBAN DE68 870520003115024672  
BIC WELADED1FGX